




# SUBMITTAL SHEET for FlexaBoot

## FlexaBoot Acoustical Return Air Boot Return Air Grilles & Transfer

<b>CODES/STANDARDS</b>	Listed and labeled by Underwriters' Laboratories, Inc., as a Class 1 Air Duct, Standard 181. It complies with the latest NFPA Bulletins 90A and 90B. Meets FHA and other U.S. government agency standards. Flame spread: not over 25. Smoke developed: not over 50. Underwriters' Laboratories, Inc. – UL 2043 "Discrete Products Installed in Air-Handling Spaces."		
<b>TEMPERATURE RANGE</b>	- 0° F to 200° F.		
<b>FLEXABOOT SIZES, ID (4 per carton)</b>	<input type="checkbox"/> 10" dia. (for 22x10 Neck Return Grille)		
<b>FLEXABOOT SIZES, ID (3 per carton)</b>	<input type="checkbox"/> 16" dia. (for 22x22 Neck Return Grille)		
<b>OPTION</b>	<input type="checkbox"/> 22x10 SQ-RD Adaptor with 10" RD Neck		
<b>OPTION</b>	<input type="checkbox"/> 22x22 SQ-RD Adaptor with 16" RD Neck		
<b>RATED VELOCITY</b>	5000 fpm		
<b>MAX RATED PRESSURE (inches water column)</b>	<table border="1"> <tr> <td><input type="checkbox"/> 1.0 inch (10 in. dia.)</td> </tr> <tr> <td><input type="checkbox"/> 1.2 inch (16 in. dia.)</td> </tr> </table>	<input type="checkbox"/> 1.0 inch (10 in. dia.)	<input type="checkbox"/> 1.2 inch (16 in. dia.)
<input type="checkbox"/> 1.0 inch (10 in. dia.)			
<input type="checkbox"/> 1.2 inch (16 in. dia.)			
<b>NEGATIVE</b>			



Each FlexaBoot assembly is supplied from the factory with:

- One FlexFlow Elbow (maintains 90° turn in flex duct)
- One FlexTie hanger strap for 10" dia. – (Two FlexTie hanger straps for 16" dia.)
- Acoustical flex duct is supplied with factory installed metal collars on both ends (one male and one female) mechanically attached and sealed with UL listed tape.

JOB _____	P.O. NO. _____
LOCATION _____	JOB NO. _____
ENGINEER _____	REPRESENTATIVE _____
CONTRACTOR _____	
Certified Correct	Certified Correct
BY _____	BY _____
TITLE _____	TITLE _____
DATE _____	DATE _____

THERMAFLEX® - a Division of Flexible Technologies, Inc., a subsidiary of Smiths Group plc.

*Customer Service Departments:*

- 528 Carwellyn Rd. • Abbeville, SC 29620 • 864-459-5441
- 9101 Perkins St. • Pico Rivera, CA 90660 • 562-801-1634
- 1040A Jayson Court • Mississauga, Ontario L4W 2V5 • 905-602-9660

[www.flexflowelbow.com](http://www.flexflowelbow.com)